

## Ordering Information



For the detailed listing of country and product specific approvals, refer to the Approvals Quick Reference Guide (document 108MI756) at Bently.com.



An isolated base ('06' thru '09', or '11', '12' in Mounting Base Option) is required when '04' Agency Approval Option is selected.

## Two-wire Transducer

### 9200-AA-BB-CC-DD

#### A: Transducer Mounting Angle/Minimum Operating Frequency Option

|           |                           |
|-----------|---------------------------|
| <b>01</b> | 0 ±2.5, 4.5 Hz (270 cpm)  |
| <b>02</b> | 45 ±2.5, 4.5 Hz (270 cpm) |
| <b>03</b> | 90 ±2.5, 4.5 Hz (270 cpm) |
| <b>06</b> | 0 ±100, 10 Hz (600 cpm)   |
| <b>09</b> | 0 ±180, 15 Hz (900 cpm)   |

#### B: Connector/Cable Option

|           |                                     |
|-----------|-------------------------------------|
| <b>01</b> | Top Mount (no cable)                |
| <b>02</b> | Side Mount (no cable)               |
| <b>05</b> | Terminal block top mount (no cable) |

#### 10 through 50

Integral hardline cable (see Figure 7 for example). Option number corresponds to cable length in feet. Standard cable lengths are shown below. Other cable lengths between 7 feet and 50 feet may be available through custom products. When ordering for hazardous area

|           |                     |
|-----------|---------------------|
| <b>10</b> | 10 feet (3.0 meter) |
| <b>15</b> | 15 feet (4.6 meter) |

|           |                      |
|-----------|----------------------|
| <b>22</b> | 22 feet (6.7 meter)  |
| <b>32</b> | 32 feet (9.8 meter)  |
| <b>50</b> | 50 feet (15.2 meter) |

#### C: Mounting Base Option

|           |  |
|-----------|--|
| <b>01</b> | Circular; 1/4-20 UNC stud  |
| <b>02</b> | Circular; 1/4-28 UNF stud  |
| <b>03</b> | Rectangular flange   |
| <b>04</b> | Circular; with three 8-32 threaded studs on a 44 mm (1.75 in) diameter bolt circle |
| <b>05</b> | No base; 1/2-20 UNF-3A stud  |
| <b>06</b> | Isolated circular 1/4-20 UNC stud  |
| <b>07</b> | Isolated circular 1/4-28 UNF stud  |
| <b>08</b> | Isolated rectangular flange  |
| <b>09</b> | Isolated circular 5/8-18 UNF stud  |
| <b>10</b> | Circular; M10X1 stud   |
| <b>11</b> | Isolated circular M10X1  |
| <b>12</b> | Isolated circular 1/2-20 UNF-2A  |

#### D: Agency Approval Option

|           |              |
|-----------|--------------|
| <b>00</b> | No Approvals |
| <b>01</b> | CSA          |
| <b>04</b> | ATEX/IECEX   |