

MANUFACTURER-SOURCE TECHNICAL REFERENCE

ICS Triplex T7481A

T7481A Evidence-Bounded Product Information Manual

Rockwell Automation / ICS Triplex Regent Plus monitored guarded output module

DOCUMENT SCOPE

Independent Apter Power manual compiled only from the cited Rockwell Automation / ICS Triplex manufacturer sources. No product photograph is included.

Product / lookup identity	ICS Triplex T7481A
Reference number	T7481A
Document basis	Published Rockwell Automation / ICS Triplex product records, PDFs, and manuals listed on page 3

**Product page**

<https://www.apterpower.com/ICS-Triplex/t7481a>
Apter Power contact

sales13@apterpower.com | +86 180 3023 5313

Workflow and system context

Rockwell Automation / ICS Triplex T7481A is an evidence-bounded Regent Plus monitored guarded output module in the ICS Triplex installed-base context. System role: It provides sixteen guarded outputs in two groups of eight with automatic testing and open/short field-wiring diagnostics.

- | | |
|----|--|
| 01 | System Inputs: It provides sixteen guarded outputs in two groups of eight with automatic testing and open/short field-wiring diagnostics. |
| 02 | Processing: The module interfaces to the triplicated Safetybus and uses dual-redundant output switching. Project load, field wiring, fuse and safety logic must match the certified application. |

Published context and boundaries

- | | |
|----|--|
| 01 | Verify the complete Rockwell Automation / ICS Triplex T7481A nameplate, revision and installed-system documentation before use. |
| 02 | T7481A is distinct from T7481, T7484 and T7488/T7488A; do not merge their minimum loads or voltage classes. |
| 03 | Current formal lifecycle phase, origin, HS code, dimensions and logistics weight remain HOLD without exact Rockwell Automation / ICS Triplex evidence. |

Verification and release checks

01	Verify the complete Rockwell Automation / ICS Triplex T7481A nameplate, revision and installed-system documentation before use.
02	T7481A is distinct from T7481, T7484 and T7488/T7488A; do not merge their minimum loads or voltage classes.
03	De-energize and follow the site's approved electrical and process-safety procedure before disturbing hardware or field wiring.
04	Back up controller, network, I/O, addressing and configuration data before replacement or firmware work.
05	Verify every companion module, termination unit, cable, connector and power source from approved drawings.
06	Do not copy electrical, communication, mechanical or lifecycle values from a related model or successor.

Identity and release controls

Verification Status	Verified Exact Model
---------------------	----------------------

Official Rockwell Automation / ICS Triplex sources

Rockwell Automation / ICS Triplex Regent Plus Reference Manual	https://literature.rockwellautomation.com/idc/groups/literature/documents/rm/icstt-rm056_-en-p.pdf
--	---