

MANUFACTURER-SOURCE TECHNICAL REFERENCE

General Electric MIVII3000E00HI00

MIVII3000E00HI00 Evidence-Bounded Product Information Manual

GE Vernova requested MIV II 3000 voltage and frequency relay configuration

DOCUMENT SCOPE

Independent Apter Power manual compiled only from the cited GE Vernova manufacturer sources. No product photograph is included.

Product / lookup identity	General Electric MIVII3000E00HI00
Reference number	MIVII3000E00HI00
Document basis	Published GE Vernova product records, PDFs, and manuals listed on page 3



Product page

<https://www.apterpower.com/General-Electric/mivii3000e00hi00-configuration-verification>

Apter Power contact

sales13@apterpower.com | +86 180 3023 5313

Workflow and system context

General Electric MIVII3000E00HI00 is an evidence-bounded requested MIV II 3000 voltage and frequency relay configuration. System role: MIV II 3000 combines phase and ground voltage protection with two frequency elements, metering, event functions and Modbus serial communications.

- | | |
|----|--|
| 01 | System Inputs: MIV II 3000 combines phase and ground voltage protection with two frequency elements, metering, event functions and Modbus serial communications. |
| 02 | Processing: Verify the full nameplate, voltage-input range, control-power code, I/O option and communication option before wiring or setting replacement. |

Published context and boundaries

- | | |
|----|--|
| 01 | Verify the complete General Electric MIVII3000E00HI00 physical label and installed-system documentation before use. |
| 02 | Manufacturing is discontinued and GE recommends P94V or 350 alternatives; neither is an unconditional drop-in replacement. |
| 03 | Origin and HS code remain unpublished unless an exact manufacturer record or the physical package label establishes them. |

Verification and release checks

01	Verify the complete General Electric MIVII3000E00HI00 label, revision and installed-system documentation before use.
02	Manufacturing is discontinued and GE recommends P94V or 350 alternatives; neither is an unconditional drop-in replacement.
03	De-energize the equipment and follow the site's approved electrical and process-safety procedure before disturbing hardware or wiring.
04	Back up controller, drive, network and configuration data before replacement, migration or firmware work.
05	Verify every companion module, cable, connector, termination and power source from approved drawings.
06	Do not copy electrical, communication, mechanical or lifecycle values from a related model or successor.

Identity and release controls

Verification Status	Family And 3000 Function Verified Full Suffix Decode Hold
---------------------	---

Official GE Vernova sources

GE Vernova MIV II Legacy Product Page	https://www.gevernova.com/grid-solutions/automation/protection-control-metering/miv-ii-legacy
GE Vernova MIV II Brochure	https://www.gevernova.com/grid-solutions/products/brochures/mivii.pdf