

MANUFACTURER-SOURCE TECHNICAL REFERENCE

Siemens 6ES7307-1EA01-0AA0

6ES7307-1EA01-0AA0 Evidence-Bounded Product Information Manual

Siemens SIMATIC S7-300 PS307 regulated power supply

DOCUMENT SCOPE

Independent Apter Power manual compiled only from the cited Siemens manufacturer sources. No product photograph is included.

Product / lookup identity	Siemens 6ES7307-1EA01-0AA0
Reference number	6ES7307-1EA01-0AA0
Document basis	Published Siemens product records, PDFs, and manuals listed on page 3



Product page

<https://www.apterpower.com/Siemens/6es7307-1ea01-0aa0>

Apter Power contact

sales13@apterpower.com | +86 180 3023 5313

Workflow and system context

Siemens 6ES7307-1EA01-0AA0 is an evidence-bounded SIMATIC S7-300 PS307 regulated power supply. System role: It converts 120/230 V AC input to a regulated 24 V DC, 5 A output for the documented SIMATIC installation.

- | | |
|----|---|
| 01 | System Inputs: It converts 120/230 V AC input to a regulated 24 V DC, 5 A output for the documented SIMATIC installation. |
| 02 | Processing: Use only with the exact host, terminal base, cable, firmware and engineering configuration documented for the installed system. |

Published context and boundaries

- | | |
|----|---|
| 01 | Verify the complete Siemens 6ES7307-1EA01-0AA0 physical label and installed-system documentation before use. |
| 02 | Verify the mains selector, protective conductor, load current, wiring and enclosure conditions before energization. |
| 03 | Origin and HS code remain unpublished unless an exact manufacturer record or the physical package label establishes them. |

Verification and release checks

01	Verify the complete Siemens 6ES7307-1EA01-0AA0 label, revision and installed-system documentation before use.
02	Verify the mains selector, protective conductor, load current, wiring and enclosure conditions before energization.
03	De-energize the equipment and follow the site's approved electrical and process-safety procedure before disturbing hardware or wiring.
04	Back up controller, drive, network and configuration data before replacement, migration or firmware work.
05	Verify every companion module, cable, connector, termination and power source from approved drawings.
06	Do not copy electrical, communication, mechanical or lifecycle values from a related model or successor.

Identity and release controls

Verification Status	Verified Evidence Bounded
---------------------	---------------------------

Official Siemens sources

S7-300 Module Data - Equipment Manual (A5E00105505-AK)	https://cache.industry.siemens.com/dl/files/629/8859629/att_55794/v1/s7300_module_data_manual_en-US_en-US.pdf
---	---