

MANUFACTURER-SOURCE TECHNICAL REFERENCE

General Electric IC693MDL740

Product Reference

Emerson / GE Vernova Series 90-30 sixteen-point positive-logic DC output module

DOCUMENT SCOPE

Independent Apter Power manual compiled only from the cited Emerson / GE Vernova manufacturer sources. No product photograph is included.

Product / lookup identity	General Electric IC693MDL740
Reference number	IC693MDL740
Document basis	Published Emerson / GE Vernova product records, PDFs, and manuals listed on page 3



Product page

<https://www.apterpower.com/General-Electric/ic693mdl740>
Apter Power contact

sales13@apterpower.com | +86 180 3023 5313

Product role and published parameters

WHAT IT IS, WHAT IT DOES, AND WHERE IT FITS

General Electric IC693MDL740 is an evidence-bounded Series 90-30 sixteen-point positive-logic DC output module. System role: The official system-manual installed-base table identifies IC693MDL740 as a 12/24 Vdc positive-logic output module with sixteen points and a 0.5 A class. System context: Emerson / GE Vernova Series 90-30 sixteen-point positive-logic DC output module.

Published field	Manufacturer-published value or verified identity note
Exact requested identity	IC693MDL740
Product class	Series 90-30 sixteen-point positive-logic DC output module
Exact model	IC693MDL740
Module class	Series 90-30 output
Nominal output	12/24 Vdc
Published current class	0.5 A
Points and logic	16, positive logic

System function and signal path

- 01 System Inputs: The official system-manual installed-base table identifies IC693MDL740 as a 12/24 Vdc positive-logic output module with sixteen points and a 0.5 A class.
- 02 Processing: Use only with the exact host, terminal base, cable, firmware and engineering configuration documented for the installed system.

Applications, answers, and official sources

1 Installed-base maintenance: Supports evidence-led identification and replacement planning for General Electric IC693MDL740.

2 System documentation: Provides a source-traceable boundary for the documented PACSystems RX3i-compatible Series 90-30 I/O installed base configuration.

3 Commissioning review: Guides identity, companion-hardware, wiring and controlled functional checks before return to service.

4 Migration assessment: Separates exact-model facts from successor, sibling and family-level information.

Frequently asked questions

What is General Electric IC693MDL740?	It is an evidence-bounded Series 90-30 sixteen-point positive-logic DC output module; this page is limited to the cited manufacturer evidence.
Is the exact identity verified?	Verified Evidence Bounded Existing Identity.
What is its system role?	The official system-manual installed-base table identifies IC693MDL740 as a 12/24 Vdc positive-logic output module with sixteen points and a 0.5 A class.
Which installed-base context is documented?	PACSystems RX3i-compatible Series 90-30 I/O installed base.
Are related models automatic substitutes?	No. A sibling, repair code, suffix or engineering replacement is not an unconditional drop-in approval.
Must the physical label be checked?	Yes. Verify the model, revision, firmware and all order or configuration suffixes.

Official Emerson / GE Vernova sources

PACSystems RX3i System Manual (GFK-2314AG)	https://discreteautomation.emerson.com/zh-CN/sfsites/c/sfc/servlet.shepherd/document/download/069QA00000WYf7YAH
--	---