

MANUFACTURER-SOURCE TECHNICAL REFERENCE

Bently Nevada

146056-38-10-02-02-05

146056-38-10-02-02-05 Evidence-Bounded Product Information Manual

Baker Hughes / Bently Nevada configured 3300 ceramic-capped proximity probe with stainless-steel tubing

DOCUMENT SCOPE

Independent Apter Power manual compiled only from the cited Baker Hughes / Bently Nevada manufacturer sources. No product photograph is included.

Product / lookup identity	Bently Nevada 146056-38-10-02-02-05
Reference number	146056-38-10-02-02-05
Document basis	Published Baker Hughes / Bently Nevada product records, PDFs, and manuals listed on page 3

**Product page**

<https://www.apterpower.com/Bently-Nevada/146056-38-10-02-02-05>
Apter Power contact

sales13@apterpower.com | +86 180 3023 5313

Workflow and system context

Bently Nevada 146056-38-10-02-02-05 is an evidence-bounded configured 3300 ceramic-capped proximity probe with stainless-steel tubing. System role: It is a 3/8-24 UNF 146056 ceramic-capped probe with rear fitting and stainless-steel tubing for front-and-rear environmental sealing after correct installation.

01	System Inputs: It is a 3/8-24 UNF 146056 ceramic-capped probe with rear fitting and stainless-steel tubing for front-and-rear environmental sealing after correct installation.
02	Processing: Gap and secure the probe before tightening the rear fitting, then preserve the documented total system length with the matching extension cable and Proximitor Sensor.

Published context and boundaries

01	Verify the complete Bently Nevada 146056-38-10-02-02-05 physical label and installed-system documentation before use.
02	The rear fitting leaves the factory unsealed and becomes sealed only after correct installation and tightening; do not transfer 146054 rear-exposure rules in reverse.
03	Origin and HS code remain unpublished unless an exact manufacturer record or the physical package label establishes them.

Verification and release checks

01	Verify the complete Bently Nevada 146056-38-10-02-02-05 label, revision and installed-system documentation before use.
02	The rear fitting leaves the factory unsealed and becomes sealed only after correct installation and tightening; do not transfer 146054 rear-exposure rules in reverse.
03	De-energize the equipment and follow the site's approved electrical and process-safety procedure before disturbing hardware or wiring.
04	Back up controller, drive, network and configuration data before replacement, migration or firmware work.
05	Verify every companion module, cable, connector, termination and power source from approved drawings.
06	Do not copy electrical, communication, mechanical or lifecycle values from a related model or successor.

Identity and release controls

Verification Status	Verified Evidence Bounded
---------------------	---------------------------

Official Baker Hughes / Bently Nevada sources

3300 Ceramic Capped Probe Datasheet 172932	https://dam.bakerhughes.com/m/7d895c04a26511b2/original/3300-Ceramic-Capped-Probe-Datasheet-172932-pdf.pdf
--	---