

MANUFACTURER-SOURCE TECHNICAL REFERENCE

General Electric IC693MDL740

IC693MDL740 Evidence-Bounded Product Information Manual

Emerson / GE Vernova Series 90-30 sixteen-point positive-logic DC output module

DOCUMENT SCOPE

Independent Apter Power manual compiled only from the cited Emerson / GE Vernova manufacturer sources. No product photograph is included.

Product / lookup identity	General Electric IC693MDL740
Reference number	IC693MDL740
Document basis	Published Emerson / GE Vernova product records, PDFs, and manuals listed on page 3



Product page

<https://www.apterpower.com/General-Electric/ic693mdl740>

Apter Power contact

sales13@apterpower.com | +86 180 3023 5313

Workflow and system context

General Electric IC693MDL740 is an evidence-bounded Series 90-30 sixteen-point positive-logic DC output module. System role: The official system-manual installed-base table identifies IC693MDL740 as a 12/24 Vdc positive-logic output module with sixteen points and a 0.5 A class.

- | | |
|----|--|
| 01 | System Inputs: The official system-manual installed-base table identifies IC693MDL740 as a 12/24 Vdc positive-logic output module with sixteen points and a 0.5 A class. |
| 02 | Processing: Use only with the exact host, terminal base, cable, firmware and engineering configuration documented for the installed system. |

Published context and boundaries

- | | |
|----|---|
| 01 | Verify the complete General Electric IC693MDL740 physical label and installed-system documentation before use. |
| 02 | Verify revision-specific grouping, protection, inrush, leakage and terminal wiring in the exact module instructions before use. |
| 03 | Origin and HS code remain unpublished unless an exact manufacturer record or the physical package label establishes them. |

Verification and release checks

01	Verify the complete General Electric IC693MDL740 label, revision and installed-system documentation before use.
02	Verify revision-specific grouping, protection, inrush, leakage and terminal wiring in the exact module instructions before use.
03	De-energize the equipment and follow the site's approved electrical and process-safety procedure before disturbing hardware or wiring.
04	Back up controller, drive, network and configuration data before replacement, migration or firmware work.
05	Verify every companion module, cable, connector, termination and power source from approved drawings.
06	Do not copy electrical, communication, mechanical or lifecycle values from a related model or successor.

Identity and release controls

Verification Status	Verified Evidence Bounded Existing Identity
---------------------	---

Official Emerson / GE Vernova sources

PACSystems RX3i System Manual (GFK-2314AG)	https://discreteautomation.emerson.com/zh-CN/sfsites/c/sfc/servlet.shepherd/document/download/069QA00000WYI7YAH
---	---