


MANUFACTURER-SOURCE TECHNICAL REFERENCE

Bently Nevada CB2W100-125

CB2W100-125 Evidence-Bounded Product Information Manual

Baker Hughes / Bently Nevada CB2W100 two-wire transducer interconnect cable



DOCUMENT SCOPE

Independent Apter Power manual compiled only from the cited Baker Hughes / Bently Nevada manufacturer sources. No product photograph is included.

Product / lookup identity	Bently Nevada CB2W100-125
Reference number	CB2W100-125
Document basis	Published Baker Hughes / Bently Nevada product records, PDFs, and manuals listed on page 3



Product page

<https://www.apterpower.com/Bently-Nevada/cb2w100-125>

Apter Power contact

sales13@apterpower.com | +86 180 3023 5313

Workflow and system context

Bently Nevada CB2W100-125 is an evidence-bounded CB2W100 two-wire transducer interconnect cable. System role: It is a 125 ft (38.1 m) CB2W100 shielded interconnect cable with isolated two-socket splash-proof connector and blunt-cut field end.

- | | |
|----|---|
| 01 | System Inputs: It is a 125 ft (38.1 m) CB2W100 shielded interconnect cable with isolated two-socket splash-proof connector and blunt-cut field end. |
| 02 | Processing: Use only with a documented compatible two-wire transducer and monitor input, and apply the sensor-specific restrictions in the current datasheet. |

Published context and boundaries

- | | |
|----|---|
| 01 | Verify the complete Bently Nevada CB2W100-125 physical label and installed-system documentation before use. |
| 02 | CB2W100 is a cable, not a sensor; the splash-proof version is not recommended with the 200350 accelerometer. |
| 03 | Origin and HS code remain unpublished unless an exact manufacturer record or the physical package label establishes them. |

Verification and release checks

01	Verify the complete Bently Nevada CB2W100-125 label, revision and installed-system documentation before use.
02	CB2W100 is a cable, not a sensor; the splash-proof version is not recommended with the 200350 accelerometer.
03	De-energize the equipment and follow the site's approved electrical and process-safety procedure before disturbing hardware or wiring.
04	Back up controller, drive, network and configuration data before replacement, migration or firmware work.
05	Verify every companion module, cable, connector, termination and power source from approved drawings.
06	Do not copy electrical, communication, mechanical or lifecycle values from a related model or successor.

Identity and release controls

Verification Status	Verified Evidence Bounded
---------------------	---------------------------

Official Baker Hughes / Bently Nevada sources

190501 Velomitor CT Transducer Datasheet 141636	https://dam.bakerhughes.com/m/7fd1c31f3265f0a6/original/190501-Velomitor-CT-Transducer-Datasheet-141636-pdf.pdf
--	---