

FC-PSUNI2424 SPS6061-LF

600 W Safety Manager Power Supply

Controlled Installation Scope

This field guide applies to the exact Honeywell FC-PSUNI2424 SPS6061-LF 600 W Safety Manager Power Supply. Confirm the physical nameplate, matched hardware and controlled project record before work starts.

Model-Specific Checks

1. Verify SPS6061-LF and FC-PSUNI2424 markings.
2. Isolate and lock out all power sources.
3. Check cabinet current and dissipation limits.
4. Maintain cooling clearances and protective earth.
5. Measure DC output and alarms before reconnecting loads.

Official Manufacturer Basis

Honeywell Safety Manager Hardware Reference EP-SM.MAN.6284
<https://prod-edam.honeywell.com/content/dam/honeywell-edam/pmt/hps/products/pas/safety-systems/safety-manager/pmt-hps-safety-manager-hardware-reference-ep-sm-man-6284-r162.pdf>

Apter Power - Industrial Automation Support

Sales: sales13@apterpower.com

WhatsApp / Phone: +86 180 3023 5313

Web: www.apterpower.com

Send the exact model, nameplate, revision and required quantity.

