

CC-TDIL51 51307083-175

Non-redundant 24 VDC Digital Input IOTA

Controlled Installation Scope

This field guide applies to the exact Honeywell CC-TDIL51 51307083-175 Non-redundant 24 VDC Digital Input IOTA. Confirm the physical nameplate, matched hardware and controlled project record before work starts.

Model-Specific Checks

1. Use only with CC-PDIL51.
2. Set internal/external field power correctly.
3. Verify ON/OFF thresholds at the field device.
4. Observe isolation and grounding requirements.
5. Test every used input and diagnostic indication.

Official Manufacturer Basis

Honeywell Experion Series-C I/O Specification EP03-490-520
https://prod-edam.honeywell.com/content/dam/honeywell-edam/pmt/hps/products/pas/experion-pks/i-o-modules/series-c-i-o-modules/EP03-490-520_V10_SCIO_1_5.pdf?download=false

Apter Power - Industrial Automation Support

Sales: sales13@apterpower.com

WhatsApp / Phone: +86 180 3023 5313

Web: www.apterpower.com

Send the exact model, nameplate, revision and required quantity.

