

T8850C

Trusted Conformal-Coated 40-Channel Analog or Digital Output FTA

Controlled Installation Scope

This field guide applies to the exact ICS Triplex T8850C Trusted Conformal-Coated 40-Channel Analog or Digital Output FTA. Confirm the physical nameplate, matched hardware and controlled project record.

Model-Specific Checks

1. Verify the T8850C nameplate; the coating suffix does not change the published electrical ratings.
2. Preserve coating integrity and use ESD-safe handling during inspection or replacement.
3. Confirm output module, cables, T8290 field power and group-loading design.
4. Do not infer additional environmental approvals from coating alone; follow the site certificate set.
5. Test all used channels and diagnostics, then retain a coating-inspection record before release.

Official Basis

Rockwell Automation PD-T8850 Trusted 40 Channel Analog or Digital Output FTA
https://literature.rockwellautomation.com/idc/groups/literature/documents/rm/icstt-rm452_-en-p.pdf

Apter Power - Industrial Automation Support

Sales: sales13@apterpower.com

WhatsApp / Phone: +86 180 3023 5313

Web: www.apterpower.com

Send the exact model, nameplate and required quantity.

