

MANUFACTURER-SOURCE TECHNICAL REFERENCE

Bently Nevada 330130-085-10-00

Installation Guide

3300 XL standard extension cable

DOCUMENT SCOPE

Apter Power product reference prepared from product-specific Baker Hughes / Bently Nevada technical information. Confirm the complete product identity and installed-system requirements before use. No product photograph is included.

Product / lookup identity	Bently Nevada 330130-085-10-00
Reference number	330130-085-10-00
Document basis	Baker Hughes / Bently Nevada technical documents listed on page 3



Product page

<https://www.apterpower.com/Bently-Nevada/330130-085-10-00>

Apter Power contact

sales13@apterpower.com | +86 180 3023 5313

Workflow and system context

Bently Nevada 330130-085-10-00 is a 3300 XL standard extension cable with an 8.5 m cable length, FluidLoc cable construction and no agency-approval option. It is used as a 3300 XL standard extension cable within the matched Bently Nevada machinery-monitoring installation.

- | | |
|----|---|
| 01 | System Inputs: 3300 XL standard extension cable |
| 02 | Processing: Bently Nevada 330130-085-10-00 is a 3300 XL standard extension cable with an 8.5 m cable length, FluidLoc cable construction and no agency-approval option. |

Published context and boundaries

- | | |
|----|--|
| 01 | Calculate the combined probe and extension-cable length before installation, then match it to the selected 330180 Proximitor sensor system length. |
| 02 | Verify model 330130-085-10-00 and the complete order code on the physical label before use. |
| 03 | Match every 330130-085-10-00 connector, terminal, cable and companion assembly before moving field wiring. |

Verification and release checks

01	Verify model 330130-085-10-00 and the complete order code on the physical label before use.
02	Calculate the combined probe and extension-cable length before installation, then match it to the selected 330180 Proximitor sensor system length.
03	Match every 330130-085-10-00 connector, terminal, cable and companion assembly before moving field wiring.
04	Back up the applicable controller, monitor, HMI or I/O configuration before replacing 330130-085-10-00.
05	Isolate energy and follow the approved site safety procedure before handling 330130-085-10-00.
06	Follow ESD controls and protect 330130-085-10-00 connectors and printed-circuit assemblies during handling.

Identity and release controls

Verification Status	Verified Product Reference
---------------------	----------------------------

Official Baker Hughes / Bently Nevada sources

3300 XL 8 mm Proximity Transducer System Datasheet	https://dam.bakerhughes.com/m/23d2a1de24360b13/original/3300-XL-8mm-Proximity-Transducer-System-Datasheet-141194-pdf.pdf
--	---