

Allen-Bradley 1756-PA72

Installation and Verification Reference

ControlLogix standard AC chassis power supply

DOCUMENT SCOPE

Apter Power product reference prepared from product-specific Rockwell Automation technical information. Confirm the complete product identity and installed-system requirements before use. No product photograph is included.

Product / lookup identity	Allen-Bradley 1756-PA72
Reference number	1756-PA72
Document basis	Rockwell Automation technical documents listed on page 3



Product page

<https://www.apterpower.com/Allen-Bradley/1756-pa72>

Apter Power contact

sales13@apterpower.com | +86 180 3023 5313

Workflow and system context

Allen-Bradley 1756-PA72 is a standard 120/240 VAC ControlLogix chassis power supply with 75 W maximum backplane output. Its documented hardware function is ControlLogix standard AC chassis power supply.

- | | |
|----|---|
| 01 | System Inputs: ControlLogix standard AC chassis power supply |
| 02 | Processing: Allen-Bradley 1756-PA72 is a standard 120/240 VAC ControlLogix chassis power supply with 75 W maximum backplane output. |

Published context and boundaries

- | | |
|----|--|
| 01 | Confirm the 1756 chassis, AC source, protective earth, branch protection, backplane load budget and power-down state before replacing 1756-PA72. |
| 02 | Verify model 1756-PA72 and the complete order code on the physical label before use. |
| 03 | Match every 1756-PA72 connector, terminal, cable and companion assembly before moving field wiring. |

Verification and release checks

01	Verify model 1756-PA72 and the complete order code on the physical label before use.
02	Confirm the 1756 chassis, AC source, protective earth, branch protection, backplane load budget and power-down state before replacing 1756-PA72.
03	Match every 1756-PA72 connector, terminal, cable and companion assembly before moving field wiring.
04	Back up the applicable controller, monitor, HMI or I/O configuration before replacing 1756-PA72.
05	Isolate energy and follow the approved site safety procedure before handling 1756-PA72.
06	Follow ESD controls and protect 1756-PA72 connectors and printed-circuit assemblies during handling.

Identity and release controls

Verification Status	Verified Product Reference
---------------------	----------------------------

Official Rockwell Automation sources

ControlLogix Power Supplies Technical Data	https://literature.rockwellautomation.com/idc/groups/literature/documents/td/1756-td005_-en-e.pdf
ControlLogix Power Supply Installation Instructions	https://literature.rockwellautomation.com/idc/groups/literature/documents/in/1756-in619_-en-p.pdf