

APTER POWER PRODUCT TECHNICAL REFERENCE

200150-02-CN

Trendmaster 2000 / Trendmaster Pro Accelerometer

This is a 200150 general-purpose accelerometer for Trendmaster 2000 or Trendmaster Pro monitoring, supplied with a 3/8-24 to 3/8-24 UNF plate stud.

The piezoelectric accelerometer measures machine-casing vibration and outputs a differential voltage proportional to acceleration along its sensitive axis.

Document field	Value
Manufacturer	Bently Nevada
Prepared by	Apter Power
Document ID	AP-BN-15-200150-02-CN-TR-R2
Revision	R2
Issue date	2026-08-31

APTER POWER SALES TEAM

INDUSTRIAL AUTOMATION PRODUCT SUPPORT

Three interface paths, one controlled configuration.

WHATSAPP / PHONE

EMAIL

WEBSITE

+86 180 3023 5313

sales13@apterpower.com

www.apterpower.com



SCAN FOR PRODUCT & QUOTE

200150-02-CN

1. Product Overview and Identity

This is a 200150 general-purpose accelerometer for Trendmaster 2000 or Trendmaster Pro monitoring, supplied with a 3/8-24 to 3/8-24 UNF plate stud.

The piezoelectric accelerometer measures machine-casing vibration and outputs a differential voltage proportional to acceleration along its sensitive axis.

Model Configuration

Field	Verified value
Complete model	200150-02-CN
Manufacturer	Bently Nevada
Product description	Trendmaster 2000 / Trendmaster Pro Accelerometer

Key Features

- Exact product identifier: 200150-02-CN
- It can be used with the 200100 Dual Acceleration-to-Velocity flexiTIM Module, the 89130-01 Acceleration-to-Velocity TIM, and 1900/25 or 1900/27 monitors.
- The device is used for general machine housing measurements where vibration from rotor-related conditions must be captured at the casing.
- Choose a mounting location that transmits the target machine vibration to the accelerometer base.

2. Technical Specifications

Technical data for 200150-02-CN is organized below for engineering review and configuration control.

Parameter	Technical value
Measurement range	+/-245 m/s2 (+/-25 g)
Frequency range	10 to 1000 Hz
Sensitivity	10.2 mV/(m/s2)
Stud interface	3/8-24 to 3/8-24 UNF
Housing material	316L stainless steel

Configuration Control

Choose a mounting location that transmits the target machine vibration to the accelerometer base.

3. Functions, Applications and Components

Core Function

200150-02-CN converts machine-case acceleration along its sensitive axis into an electrical signal. The monitoring channel uses this signal to trend casing vibration and machine structural response.

Application Areas

Application	System role
Bearing housings	200150-02-CN measures casing acceleration at a rigid mounting point.
Pumps and motors	The sensor supports routine machine vibration trending.
Fans and compressors	Case response can be monitored across operating conditions.
Condition monitoring	The electrical output is routed to a compatible acceleration channel.

Compatible Components

- Specified mounting stud or adhesive interface
- Compatible accelerometer signal cable
- Acceleration or acceleration-to-velocity monitor input
- Clean, flat machine measurement surface

4. Installation Precautions

- Select a rigid measurement surface for 200150-02-CN.
- Prepare the surface for the supplied mounting option.
- Orient the sensitive axis toward the vibration direction of interest.
- Route and secure the signal cable to avoid connector loading.

Engineering FAQ - Questions 1 to 4

What engineering function does 200150-02-CN perform in its monitoring loop?

200150-02-CN converts machine-case acceleration along its sensitive axis into an electrical signal. The monitoring channel uses this signal to trend casing vibration and machine structural response.

Which measurement range applies to 200150-02-CN?

The configured measurement range for 200150-02-CN is +/-245 m/s² (+/-25 g).

What frequency range must be checked when specifying 200150-02-CN?

Use 10 to 1000 Hz for the frequency range when reviewing this complete model.

How does the sensitivity selection affect 200150-02-CN?

This configuration identifies sensitivity as 10.2 mV/(m/s²); include that value in the installation record.

Manufacturer Technical Source

200150, 200155 and 200157 Accelerometers Datasheet 164986