

6ES7132-0BL01-0XB0

Digital Output Block

COMPLETE PRODUCT INFORMATION

It provides thirty-two 24 VDC outputs in four floating groups for an ET 200B distributed I/O station.

- Provides thirty-two digital outputs
- Separates outputs into four floating groups
- Switches 24 VDC loads at 0.5 A
- Uses documented ET 200B terminal blocks

VERIFIED IDENTITY

Order number	6ES7132-0BL01-0XB0	Module designation	ET 200B-32DO electronics block
Digital outputs	32	Output grouping	Floating in groups of eight
Load voltage	24 V DC	Output current	0.5 A

Official source: Siemens ET 200B Distributed I/O Station Manual
Publication: EWA 4NEB 812 6089-02c

APTER POWER | COMPLETE PRODUCT INFORMATION

WHATSAPP / PHONE +86 180 3023 5313

EMAIL sales13@apterpower.com | WEBSITE www.apterpower.com

6ES7132-0BL01-0XB0 | PAGE 1



6ES7132-0BL01-0XB0

TECHNICAL DATA

Order number	6ES7132-0BL01-0XB0	Module designation	ET 200B-32DO electronics block
Digital outputs	32	Output grouping	Floating in groups of eight
Load voltage	24 V DC	Output current	0.5 A
Documented loads	Solenoid valves and DC contactors	Compatible terminal block	TB2/DC
Compatible terminal block	TB2-4/DC	Compatible terminal block	TB4/DC
Compatible terminal block	TB4M/DC	System	ET 200B distributed I/O

APPLICATIONS & SYSTEM COMPONENTS

Distributed solenoid control	Commands remote solenoid valves from the field station.
DC contactor output bank	Switches documented 24 VDC contactor coils.
Remote machine I/O	Places thirty-two outputs close to the controlled machine.
ET 200B output replacement	Restores the exact ET 200B electronics block and address map.

- ET 200B station and bus interface
- 24 VDC group supplies and protective devices
- approved TB2/DC or TB4/DC family terminal block
- configured PROFIBUS output address map

APTER POWER | COMPLETE PRODUCT INFORMATION

WHATSAPP / PHONE +86 180 3023 5313

EMAIL sales13@apterpower.com | WEBSITE www.apterpower.com

6ES7132-0BL01-0XB0 | PAGE 2



6ES7132-0BL01-0XB0

PRECAUTIONS & ENGINEER FAQ

PRODUCT PRECAUTIONS

- Verify the complete 6ES7132-0BL01-0XB0 marking and the assigned SIMATIC ET 200B distributed I/O station position before work.
- Isolate all applicable power and thirty-two grouped 24 vdc output circuits field energy before disconnection.
- Use ESD controls and protect keyed interfaces, exposed contacts and electronic assemblies.
- Restore power in a controlled sequence and review module, rack and host diagnostics.
- Place the connected distributed solenoid control process in the approved maintenance state.
- Record every connector, conductor, address, jumper and project identity before removal.
- Confirm the installed ET 200B station and bus interface and approved TB2/DC or TB4/DC family terminal block against the approved system record.
- Prove the intended dc contactor output bank function and retain the final acceptance result.

ENGINEER FAQ — PART 1

1	How are the outputs grouped on Siemens 6ES7132-0BL01-0XB0?	The ET 200B-32DO block provides thirty-two outputs arranged as four floating groups of eight.
2	Which load voltage and current apply to 6ES7132-0BL01-0XB0?	The documented output circuits use 24 VDC and are rated at 0.5 A.
3	Which loads are identified for 6ES7132-0BL01-0XB0?	The Siemens manual lists solenoid valves and DC contactors as suitable documented loads.

APTER POWER | COMPLETE PRODUCT INFORMATION

WHATSAPP / PHONE +86 180 3023 5313

EMAIL sales13@apterpower.com | WEBSITE www.apterpower.com

6ES7132-0BL01-0XB0 | PAGE 3



4	Which terminal blocks can mate with 6ES7132-0BL01-0XB0?	The manual lists TB2/DC, TB2-4/DC, TB4/DC and TB4M/DC terminal blocks.
---	--	--

APTER POWER | COMPLETE PRODUCT INFORMATION

WHATSAPP / PHONE +86 180 3023 5313

EMAIL sales13@apterpower.com | WEBSITE www.apterpower.com

6ES7132-0BL01-0XB0 | PAGE 4



6ES7132-0BL01-0XB0

ENGINEER FAQ & RELATED PRODUCTS

1	Why must each eight-channel supply be recorded on 6ES7132-0BL01-0XB0?	Each floating group has its own supply boundary; losing the group map can create incorrect commons or disable a bank of outputs.
2	What PROFIBUS information must be preserved with 6ES7132-0BL01-0XB0?	Retain the ET 200B station identity, configured output addresses and diagnostic behavior in the master project.
3	Can 6ES7132-0BL01-0XB0 be replaced by a similar 32DO block directly?	No. Verify the complete MLFB, ET 200B electronics-block revision, terminal block and configured station data.
4	How should 6ES7132-0BL01-0XB0 be tested after installation?	Confirm the station reaches a healthy bus state, then exercise all thirty-two outputs while checking group supplies and the correct field loads.

RELATED PRODUCTS ON APTER POWER

01	Siemens 6SE7031 7HG84 1JC2	Related industrial automation product
02	Siemens 6SE7031 7HG84 1JC1	Related industrial automation product
03	Anybus AB9001 B	Related industrial automation product
04	ABB RPBA 01 3ABD64606859	Related industrial automation product
05	Bently Nevada 330877 080 37 00	Related industrial automation product
06	Bently Nevada 330909 00 80 10 02 00	Related industrial automation product
07	Bently Nevada 330703 000 050 10 02 00	Related industrial automation product
08	Bently Nevada 330703 000 060 10 02 00	Related industrial automation product

APTER POWER | COMPLETE PRODUCT INFORMATION

WHATSAPP / PHONE +86 180 3023 5313

EMAIL sales13@apterpower.com | WEBSITE www.apterpower.com

6ES7132-0BL01-0XB0 | PAGE 5



6ES7132-0BL01-0XB0