

Westinghouse 1C31223G01

Complete Product Information

Westinghouse 1C31223G01 is a 16-position Ovation relay-output base assembly that carries G2R-style Form C relays and exposes their contacts at field terminal blocks.

WHAT THIS PRODUCT DOES

Westinghouse 1C31223G01 serves as a relay output base assembly in the Ovation I/O subsystem. It interfaces high AC or DC field switching through Form C contacts with 1C31219G01 relay-output electronics module.

Product characteristic 1 Provides sixteen relay positions for the documented relay output base assembly function.	Product characteristic 2 Handles high AC or DC field switching through Form C contacts through the specified Ovation I/O subsystem.
Product characteristic 3 Works with 1C31219G01 relay-output electronics module.	Product characteristic 4 The dedicated base supplies the mechanical relay and terminal-block interface for Ovation relay outputs.

PRODUCT-PAGE TECHNICAL SNAPSHOT

Relay positions	16
Relay style	G2R, Form C
Electronics module	1C31219G01
Field interface	Relay contacts brought to terminal blocks

IMPORTANT NOTICE	Use 1C31223G01 only with 1C31219G01 relay-output electronics module; verify the field interface and controlled configuration before energizing the subsystem.
-------------------------	---

APTERPOWER SALES TEAM
WhatsApp / Phone: +86 180 3023 5313
Email: sales13@apterpower.com
Scan the approved WhatsApp code for model-specific support.



Features and technical data

TECHNICAL DATA SHOWN ON THE PRODUCT PAGE

Relay positions	16
Relay style	G2R, Form C
Electronics module	1C31219G01
Field interface	Relay contacts brought to terminal blocks
Module arrangement	Relay base; no standard personality module

FEATURE INTERPRETATION

Product identity Provides sixteen relay positions for the documented relay output base assembly function.	System role Handles high AC or DC field switching through Form C contacts through the specified Ovation I/O subsystem.
Service context Works with 1C31219G01 relay-output electronics module.	Return-to-service focus The dedicated base supplies the mechanical relay and terminal-block interface for Ovation relay outputs.

SIGNAL OR CONTROL PATH



The relay output base assembly belongs in the controlled Ovation I/O subsystem and works with 1C31219G01 relay-output electronics module. Its field connection, companion hardware and project configuration must be reviewed together before the channel is returned to service.

PRODUCT-PAGE TECHNICAL QUESTIONS

What function does Westinghouse 1C31223G01 perform?	It is a 16-position Ovation relay-output base assembly that carries G2R-style Form C relays and exposes their contacts at field terminal blocks.
How many channels are associated with Westinghouse 1C31223G01?	The documented configuration provides sixteen relay positions.
Which signal path is used by Westinghouse 1C31223G01?	It is used for high AC or DC field switching through Form C contacts within the specified subsystem.

Common applications

The application groups below reproduce the model-specific uses presented on the product page and connect each use to a practical verification point.

Installed-base maintenance Restores the documented relay output base assembly position without changing the approved system architecture.	Loop or channel service Supports verification of high AC or DC field switching through Form C contacts at the assigned control-system channel.
Planned replacement Provides an exact-identity replacement path when 1C31219G01 relay-output electronics module and the field interface have been confirmed.	Commissioning support Allows the responsible engineer to prove wiring, configuration, status and response for sixteen relay positions.

APPLICATION VERIFICATION MAP

Installed-base maintenance	Confirm the documented system position and the required operating function.
Loop or channel service	Compare the restored connection or control path with the approved record.
Planned replacement	Check the physical interface and the retained configuration before startup.
Commissioning support	Record diagnostics and the final controlled response before release.

INFORMATION CARRIED INTO THE WORK RECORD

Identity record Complete marking and assigned system position.	Connection record Connector, conductor and interface arrangement as found.
Configuration record Controlled settings, application data and option state.	Acceptance record Observed status, response and release decision.

IMPORTANT NOTICE

Use the complete product identifier for every application review; a related product link is not evidence of interchangeability.

APPLICATION QUESTIONS

Which signal path is used by Westinghouse 1C31223G01?	It is used for high AC or DC field switching through Form C contacts within the specified subsystem.
Which companion hardware must be checked for Westinghouse 1C31223G01?	Confirm 1C31219G01 relay-output electronics module and the project-specific base or terminal arrangement.
What technical values should be verified before installing Westinghouse 1C31223G01?	Verify 16; also confirm g2r, form c and every applicable range or wiring selection.

Product precautions and questions

EIGHT MODEL-SPECIFIC PRECAUTIONS

- 01 Match the complete 1C31223G01 marking to the work order and installed position before removal.
- 02 Confirm 1C31219G01 relay-output electronics module before making or breaking any field connection.
- 03 Keep the assigned high AC or DC field switching through Form C contacts within the documented subsystem and range.
- 04 Record terminal designations, polarity, common and shield treatment before disconnecting conductors.
- 05 Inspect module seating, connector keying, terminal condition and strain relief before power is restored.
- 06 Restore the controlled channel configuration, range selection and alarm or timeout behavior after installation.
- 07 Check local indicators and controller diagnostics for internal, communication or channel faults during commissioning.
- 08 Prove the intended response across sixteen relay positions and record the acceptance result before release.

FREQUENTLY ASKED TECHNICAL QUESTIONS

What function does Westinghouse 1C31223G01 perform?	It is a 16-position Ovation relay-output base assembly that carries G2R-style Form C relays and exposes their contacts at field terminal blocks.
How many channels are associated with Westinghouse 1C31223G01?	The documented configuration provides sixteen relay positions.
Which signal path is used by Westinghouse 1C31223G01?	It is used for high AC or DC field switching through Form C contacts within the specified subsystem.
Which companion hardware must be checked for Westinghouse 1C31223G01?	Confirm 1C31219G01 relay-output electronics module and the project-specific base or terminal arrangement.

IMPORTANT NOTICE

Use 1C31223G01 only with 1C31219G01 relay-output electronics module; verify the field interface and controlled configuration before energizing the subsystem.

RELEASE CHECKLIST

Identity accepted	The complete product marking and assigned system position agree.
Interfaces accepted	Connections, retention and controlled configuration match the recorded condition.
Response accepted	Diagnostics and the intended technical response have been documented.

FAQ, source record and related models

ADDITIONAL TECHNICAL QUESTIONS

What technical values should be verified before installing Westinghouse 1C31223G01?	Verify 16; also confirm g2r, form c and every applicable range or wiring selection.
What connection details should be recorded for Westinghouse 1C31223G01?	Record terminal identifiers, polarity, common, shield termination, connector keying and the assigned channel before disconnection.
Which diagnostics should be reviewed when commissioning Westinghouse 1C31223G01?	Review the applicable power, communication, internal-fault and channel-status indications, then compare the controller status with the expected field condition.
Can a nearby ordering code replace Westinghouse 1C31223G01 without an engineering check?	No. Match the complete identifier, companion hardware, signal range, wiring and controlled project configuration before substitution.

MANUFACTURER EVIDENCE RECORD

Manufacturer source	Emerson Process Management, Ovation I/O Reference Manual R3-1150 Rev 3, Section 18, February 2003.
Evidence boundary	Technical statements are limited to the identified product or applicable manufacturer family.
Selection control	Use the complete ordering string and verify the installed system before purchase or installation.

RELATED MODELS ON APTERPOWER

Westinghouse 1C31238H01	Related product reference. Review the complete ordering string before selection.
Westinghouse 5X00121G01	Related product reference. Compare the required interface and system position.
Foxboro AD908AA FBM201	Related product reference. Confirm the execution independently for the intended task.

APTERPOWER SALES TEAM
 WhatsApp / Phone: +86 180 3023 5313
 Email: sales13@apterpower.com
 Scan the approved WhatsApp code for model-specific support.

