Bently Nevada 330904-00-05-05-01-00

Apter Power complete product information

Bently Nevada 330904-00-05-05-01-00 is a 3300 XL NSv proximity probe with a M8 x 1 case thread, 0.5 m integral lead and clickloc connector with protector.

01 / Product role

This 3300 XL NSv probe senses the gap to a conductive target as one part of the complete proximity transducer chain.

Parameter	Selected configuration
Probe family	3300 XL NSv
Case thread	M8 x 1
Lead armor	stainless steel armored
Unthreaded length	0 mm

Installed-system context

Context	Verified use
Sensing-chain context	330904-00-05-05-01-00 is the probe at the machine target within a 3300 XL NSv probe, cable and Proximitor arrangement.
Application scope	Use the installed system calibration and target geometry to select a supported vibration, position or phase-reference location.

02 / Exact ordered configuration

Parameter	Selected configuration
Probe family	3300 XL NSv
Case thread	M8 x 1
Lead armor	stainless steel armored
Unthreaded length	0 mm
Overall case length	50 mm
Probe lead length	0.5 m
Connector	ClickLoc connector with protector
Approval selection	no agency approval selected

Option relationship

Part prefix 330904 selects a M8 x 1 case with stainless steel lead armor. The selected unthreaded section is 0 mm, within an overall 50 mm case.

Option 05 provides a 0.5 m lead. Code 01 supplies a clickloc connector with protector; keep this connection clean and match it to the extension cable.

Technical reference: Bently Nevada 3300 XL NSv Proximity Transducer System, 147385 Rev. R.

03 / Applications and compatibility

Documented uses

Use	Engineering context
Machine vibration	Observe a suitable shaft target for relative vibration in a documented transducer installation.
Axial position	Use an approved axial position arrangement with the correct target and probe gap.
Reference signal	Provide a phase or speed reference only where the monitoring channel and target support it.
Service replacement	Preserve the M8 x 1 thread, 50 mm case and 0.5 m lead when comparing the installed probe.

The final code 00 denotes no agency approval selected. Gap, scale factor and linear range describe the matched 3300 XL NSv system, rather than this probe alone.

Technical questions

Question	Engineering answer
What sensing family does 330904-00-05-05-01-00 belong to?	It is a 3300 XL NSv probe. It works with a matched extension cable and Proximitor sensor.
Which case thread is selected for 330904-00-05-05-01-00?	The 330904 part prefix selects a M8 x 1 case thread.
Is the lead of 330904-00-05-05-01-00 armored?	Yes. The 330904 probe prefix denotes an armored version.

04 / Installation precautions

Check	Action
Isolation	Make the measurement channel and machine safe before changing the probe.
Thread fit	Confirm the M8 x 1 mount without forcing a different case thread.
Target clearance	Inspect the available target area and side-view clearance before setting the probe gap.
Cable routing	Keep the lead clear of sharp edges and protect the coaxial connector from contamination.
System length	Count the 0.5 m probe lead in the total length of the matched transducer chain.
Gap acceptance	Check the final DC gap voltage and dynamic signal under the approved site procedure.

Technical notes

Topic	Explanation
Probe configuration	330904 selects a M8 x 1 armored case with 50 mm overall length and 0.5 m lead.
System boundary	Measurement performance depends on the matched probe, extension cable, Proximitor sensor and target material.

Technical questions

Question	Engineering answer
How long is the unthreaded portion of 330904-00-05-05-01-00?	Option 00 selects 0 mm unthreaded length.
What is the overall probe case length of 330904-00-05-05-01-00?	Option 05 selects 50 mm overall case length.
How long is the integral lead on 330904-00-05-05-01-00?	Option 05 selects a 0.5 m probe lead.

05 / Supply and service reference

Question	Engineering answer
What connection is supplied with 330904-00-05-05-01-00?	Option 01 specifies a clickloc connector with protector; protect the connection during routing and installation.
Does 330904-00-05-05-01-00 alone establish the system measurement range?	No. The matched 3300 XL NSv probe, extension cable, Proximitor sensor and target calibration establish system performance.

Available unit

Bently Nevada 330904-00-05-05-01-00; Condition: New, original product. Confirm the probe and any separately supplied extension cable, sensor or connector accessories in the quotation.

Related product references

Related product	Selection note
Bently Nevada 330851-02-000-060-10-00-00	Separate catalogue reference
Bently Nevada 330851-02-000-030-10-00-00	Separate catalogue reference
Bently Nevada 330101-00-10-10-02-00	Separate catalogue reference
Bently Nevada 330101-00-20-10-02-00	Separate catalogue reference
Bently Nevada 330101-00-08-05-02-00	Separate catalogue reference
Bently Nevada 330801-28-20-050-03-02	Separate catalogue reference
Bently Nevada 330880-01-20-058-03-02	Separate catalogue reference
Bently Nevada 330880-00-00-000-03-02	Separate catalogue reference

Technical reference: Bently Nevada 3300 XL NSv Proximity Transducer System, 147385 Rev. R.