Bently Nevada 31000-28-05-00-020-03-00

Apter Power complete product information

Bently Nevada 31000-28-05-00-020-03-00 is a 31000 PPS body proximity probe housing assembly configured with a 3300 XL 8 mm probe with selectable approvals and 0.5 m probe lead.

01 / Product role

This PPS body housing gives external access to a reverse-mounted proximity probe at a machine casing.

Parameter	Selected configuration
Assembly family	31000 proximity probe housing
Housing construction	PPS body
Probe selection	3300 XL 8 mm probe with selectable approvals
Probe lead	0.5 m

Installed-system context

Context	Verified use
Machine-case context	The 31000-28-05-00-020-03-00 housing positions a proximity probe through the machinery case for an externally accessible sensing point.
Compatibility boundary	Use the selected 3300 XL 8 mm probe with selectable approvals, 0.5 m lead and no outer sleeve, retainer or retaining nut only with a verified machine opening and compatible transducer chain.

Apter Power technical support
sales13@apterpower.com | +86 18030235313

02 / Exact ordered configuration

Parameter	Selected configuration
Assembly family	31000 proximity probe housing
Housing construction	PPS body
Probe selection	3300 XL 8 mm probe with selectable approvals
Probe lead	0.5 m
Standoff option	no standoff adapter
Penetration option	2.0 in probe penetration
C plus D selection	2 in
Conduit fittings	two plugs, one 3/4-14 NPT fitting, one reducer and cable seal grip
Mounting option	no outer sleeve, retainer or retaining nut

Option relationship

The 28 probe option selects 3300 XL 8 mm probe with selectable approvals; option 05 supplies a 0.5 m lead. Match the probe and extension cable to the installed 3300 XL 8 mm transducer system before assigning measurement performance.

Option 00 specifies no standoff adapter, and 020 specifies 2.0 in probe penetration. Their selected C plus D reach is 2 in. Establish the final probe gap from the machine drawing and the transducer procedure.

Technical reference: Bently Nevada 31000 and 32000 Proximity Probe Housing Assemblies, 141610 Rev. R.

03 / Applications and compatibility

Documented uses

Use	Engineering context
Radial measurement	Position the probe at a documented radial vibration or position location on the machine casing.
Gap access	Use the external housing access to adjust the installed probe gap without dismantling the machine.
Conduit connection	Route field conduit through the 03 fitting arrangement and seal unused ports.
Installed reach	Locate the probe at the selected 2 in C plus D reach without assuming an outer sleeve is supplied.

Option 03 identifies two plugs, one 3/4-14 NPT fitting, one reducer and cable seal grip; option 00 identifies no outer sleeve, retainer or retaining nut. The conduit entry, sealing arrangement and case interface must match these selected pieces.

Technical questions

Question	Engineering answer
What housing construction does 31000-28-05-00-020-03-00 use?	The 31000 assembly uses a PPS body housing; option F00 excludes the outer sleeve, retainer and retaining nut.
Which probe option is selected on 31000-28-05-00-020-03-00?	Code 28 selects 3300 XL 8 mm probe with selectable approvals; the probe is a component of the housing assembly.
How long is the probe lead specified for 31000-28-05-00-020-03-00?	Code 05 selects 0.5 m of probe cable. Check the remaining transducer-system length with the installed extension cable and Proximitor sensor.

04 / Installation precautions

Check	Action
Isolation	Apply the site isolation procedure before opening the machine probe housing.
Mechanical fit	Check the no outer sleeve, retainer or retaining nut against the machined case opening before assembly.
Assembly support	Check the machine drawing and installed reach; option F00 omits the outer sleeve, retainer and retaining nut.
Probe clearance	Check side-view and rear-view clearance at the chosen penetration and case geometry.
Sealing	Inspect the housing seals, conduit entries and probe pressure boundary before service.
Commissioning	Set and verify the probe gap with the matched transducer components and machine stopped as required.

Technical notes

Topic	Explanation
Installation relationship	The selected C plus D reach is 2 in. Use the machine drawing and probe gap-setting procedure to establish the installed position.
Protection	The 31000 housing provides mechanical and environmental protection, not explosion-proof containment.

Technical questions

Question	Engineering answer
How does 31000-28-05-00-020-03-00 establish its standoff position?	Code 00 specifies no standoff adapter. The actual machine position also depends on penetration option 020.
What penetration is encoded in 31000-28-05-00-020-03-00?	Option 020 denotes 2.0 in probe penetration; the C plus D selection totals 2 in.
Which conduit pieces are associated with 31000-28-05-00-020-03-00?	Option 03 selects two plugs, one 3/4-14 NPT fitting, one reducer and cable seal grip. Confirm that the offered hardware corresponds to the complete assembly.

05 / Supply and service reference

Question	Engineering answer
What mounting interface is selected for 31000-28-05-00-020-03-00?	Code 00 specifies no outer sleeve, retainer or retaining nut; do not substitute a different thread or sleeve arrangement.
What does mounting option F00 mean for 31000-28-05-00-020-03-00?	F00 specifies no outer sleeve, retainer or retaining nut. Confirm that this matches the machine mounting arrangement.

Available unit

Bently Nevada 31000-28-05-00-020-03-00; Condition: New, original product. Confirm the PPS housing body, reverse-mounted probe, seals and 03 fitting set. Option F00 excludes the outer sleeve, retainer and retaining nut.

Related product references

Related product	Selection note
Bently Nevada 21000-16-05-00-105-03-02	Separate catalogue reference
Bently Nevada 31000-16-10-15-040-03-02	Separate catalogue reference
Bently Nevada 31000-16-05-00-033-03-02	Separate catalogue reference
Bently Nevada 330801-28-20-050-03-02	Separate catalogue reference
Bently Nevada 330880-01-20-058-03-02	Separate catalogue reference
Bently Nevada 330880-00-00-000-03-02	Separate catalogue reference
Bently Nevada 330880-16-00-021-03-02	Separate catalogue reference
Bently Nevada 21504-000-040-10-02	Separate catalogue reference

Technical reference: Bently Nevada 31000 and 32000 Proximity Probe Housing Assemblies, 141610 Rev. R.