GE IS220PTCCH2B

Complete Product Information

GE IS220PTCCH2B is a thermocouple input i/o pack for GE Mark VIe thermocouple I/O.

01 Thermocouple acquisition identity

Input function	Thermocouple acquisition
Input group	12 general-industry inputs
Cold-junction input	1
Updated model	IS220PTCCH2B
Earlier model	IS220PTCCH2A
Control family	Mark VIe
Interface role	I/O network to terminal board

02 Functional role and system position

IS220PTCCH2B is the updated H2 thermocouple input pack for twelve general-industry inputs plus one cold-junction input. The H2 identity separates it from the combustion-optimized H1 path.

The pack provides the processing and network interface between the thermocouple terminal board and the Mark VIe controller. Thermocouple type, channel configuration and cold-junction arrangement remain application settings.

Before replacement, preserve channel-to-sensor mapping, thermocouple type, polarity and cold-junction wiring. Acceptance should compare ambient indication and representative process channels after stabilization.

03 Engineering highlights

Temperature-channel acquisition

Converts the installed thermocouple signals for the Mark VIe control application.

Cold-junction integrity

Reliable indication depends on preserving the cold-junction arrangement and ambient stabilization.

Sensor mapping control

Thermocouple type, polarity and channel-to-sensor assignment are retained before replacement.

04 Evidence and applicability boundary

The exact H2B model is the updated pack for 12 general-industry thermocouple inputs and one cold-junction input; H1B combustion-optimized data are not transferred.

05 Sensor and cold-junction path

Installed-system service

Maintain the exact IS220PTCCH2B identity when replacing the fitted thermocouple input i/o pack.

Configuration retention

Preserve application records, channel maps or hardware settings that belong to the installed system.

Controlled troubleshooting

Use the approved system diagnostics to separate module, wiring and companion-hardware faults.

Acceptance testing

Return the system to service only after representative functions match the recorded baseline.

06 Installation and protection controls

Confirm the full marking

Match IS220PTCCH2B and every visible revision or assembly identifier.

Preserve the as-found map

Record connectors, terminals, orientation and companion hardware before removal.

Apply the approved isolation

Use the complete system maintenance procedure and prove the required isolation.

Protect the hardware

Use ESD control and prevent mechanical load on connectors or board surfaces.

Restore configuration deliberately

Reapply only the approved installed settings, wiring and application records.

Retain acceptance evidence

Keep label photographs, test results, deviations and responsible sign-off.

07 Technical notes

Installation relationship	IS220PTCCH2B belongs to the configured GE Mark VIe thermocouple I/O hardware chain; the complete installed relationship governs replacement.
Protection	Follow the approved isolation, ESD and system-specific commissioning procedure before handling IS220PTCCH2B.
Technical reference	GE Mark VIe I/O Extended Product Life Cycle Support Notice GEZ-S2026. The exact H2B model is the updated pack for 12 general-industry thermocouple inputs and one cold-junction input; H1B combustion-optimized data are not transferred.

08 Installed-system decision points

How should thermocouple type and polarity be confirmed for IS220PTCCH2B?	Identify each sensor type from the approved loop schedule and retain the positive and negative conductor mapping. A reversed or mismatched thermocouple can produce a plausible but incorrect temperature indication.
What cold-junction relationship must be checked for IS220PTCCH2B?	Confirm the documented cold-junction input and the terminal hardware that provides the reference used by the thermocouple channels. Compare its reading with a calibrated reference before accepting channel accuracy.
Which terminal-board identity should be recorded with IS220PTCCH2B?	Capture the connected terminal-board marking, connector position and all twelve channel assignments before removal. The I/O pack and terminal board must be treated as one documented measurement path.

09 Temperature-channel verification matrix

Sensor identity	Confirm thermocouple type, polarity and extension-wire relationship for every used channel. Exact model: IS220PTCCH2B.
Reference path	Verify terminal-board and cold-junction relationships before assessing measurement accuracy. Exact model: IS220PTCCH2B.
Controlled injection	Apply calibrated thermocouple or millivolt values one channel at a time. Exact model: IS220PTCCH2B.
Temperature acceptance	Record injected values, displayed readings, error and final diagnostics. Exact model: IS220PTCCH2B.

10 Published technical data - continuation

Documented platform	GE Mark VIe thermocouple I/O
Exact-model boundary	Use the complete marking and every visible revision or assembly identifier.
System-data boundary	The exact H2B model is the updated pack for 12 general-industry thermocouple inputs and one cold-junction input; H1B combustion-optimized data are not transferred.

11 Product-specific engineering FAQ

How should thermocouple type and polarity be confirmed for IS220PTCCH2B?

Identify each sensor type from the approved loop schedule and retain the positive and negative conductor mapping. A reversed or mismatched thermocouple can produce a plausible but incorrect temperature indication.

What cold-junction relationship must be checked for IS220PTCCH2B?

Confirm the documented cold-junction input and the terminal hardware that provides the reference used by the thermocouple channels. Compare its reading with a calibrated reference before accepting channel accuracy.

Which terminal-board identity should be recorded with IS220PTCCH2B?

Capture the connected terminal-board marking, connector position and all twelve channel assignments before removal. The I/O pack and terminal board must be treated as one documented measurement path.

How should the H2B revision of IS220PTCCH2B be evaluated against an H2A installation?

Use the complete H2B marking and the applicable GE revision guidance for the installed terminal arrangement. Do not assume that the later suffix is a direct replacement solely because the base model is shared.

How can an open thermocouple be distinguished from an IS220PTCCH2B channel fault?

Check pack diagnostics, terminal continuity, sensor wiring and a controlled millivolt input at the documented test point. Follow the fault as the test moves from the field circuit toward the pack.

What shielding and routing checks apply to IS220PTCCH2B?

Preserve the project-approved thermocouple extension wire, shield termination and separation from noisy power wiring. Correct unintended ground paths before judging measurement stability.

How should IS220PTCCH2B be commissioned with a simulator?

Inject controlled thermocouple or millivolt values one channel at a time, including a mid-range point, and compare pack indication with the calibrated source and controller display.

What temperature-channel record should be retained for IS220PTCCH2B?

Keep the full pack and terminal-board identities, sensor types, polarity map, cold-junction check, injected values, observed readings and final diagnostics for every used channel.

12 Lifecycle and supply boundary

The current manufacturing and manufacturer-support phase of IS220PTCCH2B is unconfirmed. Preserve its exact installed identity when planning service.

Offered reference	GE IS220PTCCH2B
Included items	the IS220PTCCH2B thermocouple input i/o pack; companion hardware and accessories only when itemized in the quotation
Identity check	Compare the complete marking, revision and connections with available unit photographs and the installed record.

13 Commissioning handover record

Sensor-type and polarity map	Retain with the complete model marking, installed asset reference and responsible acceptance sign-off.
Cold-junction verification	Retain with the complete model marking, installed asset reference and responsible acceptance sign-off.
Injected reference values	Retain with the complete model marking, installed asset reference and responsible acceptance sign-off.
Observed temperature results	Retain with the complete model marking, installed asset reference and responsible acceptance sign-off.

14 Enquiry workflow

Review your reference	Send the complete IS220PTCCH2B marking, installed-position photographs and required quantity.
Confirm the offer	Confirm the offered revision, condition, included items and documented system fit in the quotation.
Arrange dispatch	Agree quantity, dispatch date and delivery details in the quotation.

15 Related product references

Recommended model	GE IS220PSVOH1B
Recommended model	GE IS200STTCH2A
Recommended model	GE IS230SNAOH2A
Recommended model	GE IS220STAOH2A
Recommended model	GE IS220STAIH2A

Confirm the complete IS220PTCCH2B marking, installed relationship and required quantity with Apter Power.

sales13@apterpower.com | +86 18030235313